SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

## **Acoufelt PTY LTD**

Level 4, 108 King William Street, Adelaide, SA, Australia

For the following product(s):

## **Acoustic Wall Panels:**

**Acoustic Panel** 

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

## Indoor Advantage™ Gold

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.0 Conforms to the CDPH/EHLB Standard Method (CA 01350) v1.2-2017 for the school classroom, private office, and single-family residence parameters.<sup>1</sup>

<sup>1</sup> Modeled as Wall Covering

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m3 (in compliance with CDPH/EHLB Standard Method v1.2-2017.

Registration # SCS-IAQ-05507

Valid from: April 22, 2022 to April 21, 2023







Stanley Matha Kam

Stanley Mathuram, PE, Executive Vice President
SCS Global Services
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA